

Attestation of Conformity

No. 2022-298A

Cables for use in construction works Reaction to fire class D_{ca}

Company

Zhejiang Ship Electronics & Technology Co., Ltd.
No. 6, Gaoya Road
Science & Technology Zone
Jiangshan Town, Yinzhou District
Ningbo
315191 Zhejiang, China

Product description

Screened communication cable (F/FTP) with solid conductors,
2×4 twisted pairs, LSZH

Product identification

F/FTP CAT6/6A/7/7A 4X2X23AWG DUAL
Part no. D1900-D1-X

Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 50399:2011 including amendment A1:2016
- EN 60754-2:2014 including amendment A1:2020
- EN 13501-6:2018

Reaction to fire classification

Class D_{ca}-s2,d2,a1

Technical report

12223163-02, rev. 1, DANAK-19/22659


EC Cabling product ID

7340

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

This Attestation of Conformity has been revised, original issue date 9 May 2022.

Hørsholm, 23 June 2022



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department