



We help ideas meet the real world

Attestation of Conformity

No. 2016-600

Cables for use in construction works Reaction to fire class D_{ca}

Company

Zhejiang Zhaolong Cable Co., Ltd
Floor 9, Zhongmao Building,
Yong An Str., Wukang
Deqing Zhejiang
China 313200

Product description

Unscreened communication cable (U/UTP) with solid conductors
4 twisted pairs, LSZH jacket

Product identification

UTP Cat. 6 FRLSZH 4P 23 AWG
Part no. 2015613

Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendment A1:2015
- EN 50399:2011 including amendment A1:2016
- EN 13501-6:2014

Reaction to fire classification

Class D_{ca} -s2,d1

Technical report

DELTA-T213074-04, DANAK-19/16755

EC Cabling product ID

6095

This product has undergone a one-time test performed by DELTA EC Cabling Group and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR).

Hørsholm, 31 October 2016

Lars Lindskov Pedersen
Test Manager

Claude Videt
Project Manager

DELTA

Venlighedsvej 4
2970 Hørsholm
Denmark

Tel. +45 72 19 40 00
Fax +45 72 19 40 01
www.madebydelta.com/cable