

Attestation of Conformity

No. 2018-274

Cables for use in construction works Reaction to fire class D_{ca}

Company

Zhejiang Zhaolong Interconnect Technology Co.,Ltd.
Floor 9, Zhongmao Building,
Yong An Str., Wukang
Deqing, Zhejiang
China 313200

Product description

Screened communication cable (U/FTP) with solid conductors, 4 twisted pairs, LSZH jacket

Product identification

U/FTP CAT6/6A 4P 23AWG LSZH

Product references:

U/FTP CAT6 4P 23AWG LSZH; Part no. G2406-001
U/FTP CAT6A 4P 23AWG LSZH; Part no. G2503-030

Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 50399:2011 including amendment A1:2016
- EN 60754-2:2014
- EN 13501-6:2014

Reaction to fire classification

Class D_{ca}-s1,d2,a1

Technical report


T735477-01, DANAK-19/18520

EC Cabling product ID

6630

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

Hørsholm, 16 March 2018



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department