

Attestation of Conformity

No. 2018-279A

Cables for use in construction works Reaction to fire class D_{ca}

Company

Zhejiang Zhaolong Interconnect Technology Co.,Ltd.
Floor 9, Zhongmao Building,
Yong An Str., Wukang
Deqing, Zhejiang
China 313200

Product description

Screened communication cable (F/UTP) with solid conductors, 4 twisted pairs, LSZH jacket

Product identification

F/UTP CAT6/6A 4P 23AWG LSZH

Product references:

F/UTP CAT6 4P 23AWG LSZH; Part no. G2402-059
F/UTP CAT6A 4P 23AWG LSZH; Part no. G2502-036
U/UTP DF CAT6A 4P 23AWG LSZH; Part no. G2501-056

Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 50399:2011 including amendment A1:2016
- EN 60754-2:2014
- EN 13501-6:2014

Reaction to fire classification

Class D_{ca}-s2,d2,a1

Technical report

T735477-06, rev. 1, DANAK-19/18525


EC Cabling product ID

6635

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

This Attestation of Conformity has been revised, original issue date 18 March 2018.

Hørsholm, 16 January 2020



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department