



# Attestation of Conformity

No. 2017-027

## Cables for use in construction works Reaction to fire class E<sub>ca</sub>

### Company

Zhejiang Zhaolong Cable Co., Ltd  
Floor 9, Zhongmao Building,  
Yong An Str., Wukang  
Deqing Zhejiang  
China 313200

### Product description

Unscreened communication cable (U/UTP) with solid conductors  
4 twisted pairs, PVC jacket

### Product identification

U/UTP CAT6 4P 24AWG PVC  
Part no. 215111221

### Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendment A1:2015
- EN 13501-6:2014

### Reaction to fire classification

Class E<sub>ca</sub>

### Technical report

DELTA-T600959-08, DANAK-19/17193

### EC Cabling product ID

6126

This product has undergone a one-time test performed by DELTA EC Cabling Group and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR).

Hørsholm, 15 January 2017

Lars Lindskov Pedersen  
Test Manager

Dennis Andersen  
Head of Department

### DELTA – a part of FORCE Technology

Venlighedsvej 4      Tel. +45 72 19 40 00  
2970 Hørsholm      Fax +45 72 19 40 01  
Denmark      www.madebydelta.com/cable