

# Attestation of Conformity

No. 2018-301

## Cables for use in construction works Reaction to fire class E<sub>ca</sub>

### Company

Zhejiang Zhaolong Interconnect Technology Co.,Ltd.  
Floor 9, Zhongmao Building,  
Yong An Str., Wukang  
Deqing, Zhejiang  
China 313200

### Product description

Screened communication cable (F/FTP) with solid conductors, 4 twisted pairs, LSZH jacket

### Product identification

F/FTP CAT6A/7/7A 4P 23AWG PVC

### Product references:

F/FTP CAT6A 4P 23AWG PVC; Part no. G2504-028  
F/FTP CAT7 4P 23AWG PVC; Part no. G2601-006  
F/FTP CAT7A 4P 23AWG PVC; Part no. G2703-005

### Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 13501-6:2014

### Reaction to fire classification

Class E<sub>ca</sub>

### Technical report


T735477-15, DANAK-19/19015

### EC Cabling product ID

6646

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

Hørsholm, 4 April 2018



Lars Lindskov Pedersen  
Test Manager



Dennis Andersen  
Head of Department