

Compliance Statement

No. 2021-707

Screened Channel, Class E_A

Company

Domogest
19 rue Pierre Boulanger, ZI. Du Brezet
63000 Clermont-Ferrand
France

Channel Identification (3 connector model)

Horizontal cable:

ALL550XFF

RJ45 connector for telecommunications outlet, consolidation point, and patch panel:

ALLPRIC6AC2SFTP

Consolidation point cord:

ALL550XFF with plug ALLPLUC6ASFTP and jack ALLPRIC6AC2SFTP added

Terminal cord and equipment cord:

ALLCORC6ASFXXXNOZ

Patch Panel:

ALL19PPAN241UFTP (mounting support for RJ45 jack)

Generic cabling standards - Class E_A Channel requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

Technical report

12130734-01, DANAK-19/22257

EC Cabling product ID


6532

CS valid until

1 February 2023

This product has been tested by FORCE Technology up and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 27 October 2021



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department